

Message

From: Ivan FMCV [isfmcv@hopitelecom.net]
Sent: 6/8/2016 9:12:17 PM
To: Lee, Bessie [Lee.Bessie@epa.gov]
CC: FIRST MESA VLGS [sgfmcv@hopitelecom.net]
Subject: Re: ccr 2015 /public notice for arsenic dtd 3/22/16

Ok. We will make it a practice to post all notices.

From: "Lee, Bessie" <Lee.Bessie@epa.gov>
To: "FIRST MESA VLGS" <sgfmcv@hopitelecom.net>, "FIRST MESA VLGS" <isfmcv@hopitelecom.net>
Sent: Wednesday, June 8, 2016 2:04:25 PM
Subject: RE: ccr 2015 /public notice for arsenic dtd 3/22/16

Thank you very much, Ivan and Sharon, for the 2015 CCR and the Public Notice.

Please remember that you will probably have to submit the Public Notice on a quarterly basis. The water system is required to sample for Arsenic on a quarterly basis. When you get the results back and it shows that the Arsenic standard has been exceeded, a Public Notice is required to be issued/distributed to your customers. Since sampling for Arsenic is done quarterly, the Public Notice is also to be done quarterly.

~~~~~

Bessie Lee

~~~~~

Drinking Water Management Section (WTR-3-1)

U.S. Environmental Protection Agency, Region 9

75 Hawthorne Street

San Francisco, California 94105

Phone: (415) 972-3776

Fax: (415) 947-3545

E-mail: lee.bessie@epa.gov

From: FIRST MESA FMVC [mailto:sgfmcv@hopitelecom.net]
Sent: Wednesday, June 08, 2016 11:37 AM

To: Lee, Bessie <Lee.Bessie@epa.gov>; DataManager <DataManager@epa.gov>

Subject: ccr 2015 /public notice for arsnic dtd 3/22/16

06/08/2016

good morning Bessie, EPA

See attach the ccr - 2015 /public notice arsenic-03/22/2016

Hope is all complete, email if any mistakes

Thank u so much Bessie

Have good Day!

Sharon-FMCV water/sanitation svc.